



The Commonwealth of Massachusetts

Department of Fire Services

527 CMR 1.00
Section 1.12.8.2.1

Form 1

FP-056
(Rev. 4.2019)

Application for Permit, Permit, and Certificate of Completion for the
Installation or Alteration of Fuel Oil Burning Equipment and the Storage of Fuel Oil

Permit #'s: FD _____ Elec. _____ FDID#: _____ Fee Paid: \$ _____
Owner/Occupant Name: _____ Tel.#: _____
Installation Address: _____ Serviced Floor or Unit #: _____
[] Heating Unit [] Domestic Water Heater [] Power Vent Other _____
Burner: [] New [] Existing [] Location: _____
Mfg: _____
Type: _____ Model # or Size: _____ Nozzle size: _____
[] Fuel Oil [] Kerosene [] Waste Oil
Storage Tank: [] New [] Existing [] Removal Location: _____
Type: _____ Capacity: _____ gallons No. of Tanks: _____
Special requirements (or additional safety devices) _____
[] OSV valve [] Oil Line Protected

Co. Name: _____ Tel # _____

Address: _____ City: _____ Zip: _____

Completion Date: _____

Combustion Test: Gross Stack Temp.: _____ Net Stack Temp.: _____

CO2 Test: _____ Breech Draft: _____

Smoke: _____ Overfire Draft: _____ Efficiency Rating %: _____

I, the undersigned certify that the installation of fuel burning equipment has been made in accordance with M.G.L. Chapter 148 and 527 CMR 1.00
currently in effect. Furthermore, this installation has been tested in accordance with such requirements, is now in proper operating condition and
complete instructions as to its use and maintenance have been furnished to the person or whom the installation (or alteration) was made.

Installer: _____
Print Name Cert of C# Signature (no Stamp)

Address: _____ City: _____

Once signed by the fire department, this is a PERMIT for the storage of fuel oil and use of the oil burning equipment.

Approved by: _____ Date: _____

Note to Installer: Inspections will be conducted using this checklist as a guideline. Current regulations will apply.

ALL INSTALLATIONS

- All applications must be on Form 1
- Over 10,000 gallons on site requires License & Permit from local community
- Certificate of Competency required, no other license acceptable, plumbing, electrical, etc.
- Verify emergency shut-off is outside burner room
- Verify separate circuit for oil burner
- Verify presence of overhead thermal switch
- Verify presence of service switch within 3' of burner
- Verify presence of high limit controller
- Primary control has safety shutoff within 15 secs.
- Stack type primary may be easily removed
- Clear access to clean out and services panels
- No oil leaks present at burner
- Installation instructions present on site
- Combustion test results on Form 1
- Three metal screws at each joint in chimney
- IF POWER VENTER IS USED: Check air pressure switch, post purge control and secondary control. Installation instructions present.
- Draft regulator is present unless exempted
- Adequate air is present for combustion
- Adequate clearances per manufacturers listing
- Thermal valves at burner and tanks
- Listed flexible hose may be used (at burner only)
- No Teflon tape on oil line or on oil line fittings
- No compression fittings are permitted
- Solder joints made with 500 degree F solder or greater
- All oil supply and return lines must be protected from injury. All new lines must be continuously sleeved with non metallic tubing. Oil safety valves may be used on existing lines not exposed to freezing. Overhead lines require no sleeve and are permitted
- Oil supply lines and return lines to tanks exposed to freezing temperatures must come off the top of tanks
Lines for kerosene, and range oil (#1) are exempt -
- No oil leaks present at tank
- Listed oil filter is present
- Tank is UL80 or (DIB+) PV-VI 321 (under 660 gal) or UL 142 (over 600 gal)
- Thermal shutoff valve located at bottom of tank
- Vent as per NFPA 31
- Oil tank gauge must be present to determine oil level
- Inside tanks have audible fill device (vent alarm)
- Outlet cross connection at bottom of tanks must be 1/2" pipe or tubing.
- Non-combustible tank supports, tank secure.

UNENCLOSED TANKS

- Single tanks shall not be larger than 660 gallons
- Maximum aggregate capacity of unenclosed multiple tanks is 1320 gallons
- Unenclosed tanks shall be at least five feet from an internal or external flame
- Unenclosed tanks shall not obstruct service meters, service panels and shutoff valves
- Bottom outlet tanks pitched to the opening
- Tanks exposed to vehicles will be protected by barriers

ENCLOSED TANKS

- Over 660 gallon tanks enclosed by two hour fire resistive assembly
- Tank enclosures provided with 6" high tight sills or ramps
- Tank is 4" above floor supported by 12" thick masonry saddles spaced not more than eight feet on centers and 15" from top and walls of enclosure
- All oil must be transferred by pump, and connections must be at the top of the tank

ALL TANKS

- Two tanks may be cross-connected as shown in Fig. 8.9.1 NFPA 31 2011 edition
- Return lines must enter the top of tanks
- Vent pipes must be two feet from building openings
- Vent pipes must terminate 3 ft. above grade min.
- Vent pipes must have weatherproof caps
- Fill pipes must be two feet from building openings
- Fill pipes must have tamper proof identifying caps

OUTSIDE TANKS

- All UST's and tanks over 660 gallons must be installed as per NFPA 31 2011 edition
- Tank protected from physical damage
- Tanks exterior coated with organic alkyd resin or asphalt paint
- Damaged protective coatings must be recovered
- Tank does not block means of egress
- Tank mounted on continuous 4" thick slab that extends 8" beyond tank perimeter
- Tank is supported by rigid non-combustible supports